

Chaussée de Vilvorde, 156 Vilvoordsesteenweg 156 B-1120 Bruxelles/Brussel Tel.: +32 (0)2 264 03 60 Fax: +32 (0)2 268 89 58 www.apragaz.com info@apragaz.com





NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE

Certificate N° 13/IT/3309-2-REV 0

In accordance with module B of the Marine Equipment Directive 2014/90/EU on Marine Equipment

	Name	ANAF FIRE PROTECTION S.P.A.
Manufacturer	Address	Via del Commercio 4 IT - 27020 Torre d'Isola (Pavia) ITALY

<u>Concerned Equipment</u>: Portable Water Based Stored Pressure Fire Extinguishers

Type: a) FS9-J according to technical design ref. 09.860F.F000.00 and file 09.860F.9200.00

b) FS9-JF according to technical design ref. 09.870F.F000.00 and file 09.870F.9200.00

Capacities: 91

Set pressure Ps: 17,48 bar (60°C)

Test pressure Pt: 25 bar

Service temperature range: min. 0°C / max. +60°C

<u>Used Standards</u>: EN3.7:2004 A1:2007 & EN3.8:2021

The manufacturer is allowed to affix the marine wheel mark (followed by the NoBo identification n° and the year of manufacturing) to approved equipment in the conditions described in article 10 of the Directive , only if the requirements stated in module D are fully complied with.

The approval is valid until 07/01/2028

APRAGAZ, acting within the scope of its notification for the above-mentioned Directive, certifies that the types of equipment defined here above are conform to the requirements of the EN 3.7 & EN 3.8 in force and to the Marine Equipment Directive 2014/90/EU (as amended), on base of the documentation and samples supplied for review and approbation.

Approval Date : 6/02/2023

Name: B. Nève, Ir

Position

General Manager

Notified body identification number:

0029

Signature

Notified body stamp:

APRAGAZ VZW / ASBL

Notified body reference:

P4434/000