

MPA Dresden GmbH · Fuchsmühlenweg 6F · D-09599 Freiberg

Fabrik chemischer Präparate von
Dr. Richard Sthamer GmbH & Co. KG
Liebigstraße 5
22113 Hamburg
Germany

Date: 2024-01-24
Official: Mr. Frömter
Phone: +49-(0)3731- 2 03 93 165
Telefax: +49-(0)3731- 2 03 93 110
e-mail: christoph.froemter@kiwa.com
Post number: 24A0162
Project number: 20230898
(Please state in case of reply!)

Results of a fire extinguishing test referring to ICAO Airport services manual, part 1, chapter 8, fourth edition, 2015, using simulated sea water
Foam concentrate STHAMEX MARINE 6% F-15 #9641

Dear Sir or Madam

Corresponding to your order we have carried out on 2023-10-26 a fire extinguishing test referring to clause 8.1.8 of the above standard, using the foam concentrate STHAMEX MARINE 6% F-15 #9641 (6% usage concentration) of the manufacturer Fabrik chemischer Präparate von Dr. Richard Sthamer GmbH & Co. KG.

The test was carried out largely in accordance with the specifications of clause 8.1.8 of the above standard, performance class B. The deviations in the test procedures are listed below:

- The foam solution was prepared with simulated seawater according to EN 1568:2018.

Herewith we confirm the obtained test results as follows:

ICAO performance class B requirements were fulfilled using a 6% foam solution with simulated seawater.

The extinguishing test referring to clause 8.1.8 of ICAO Airport services manual, part 1, chapter 8, fourth edition, 2015 is a partial test only and not representative of a complete type test of the foam concentrate. The use of simulated seawater is a special case, which is not covered by a type test according to the above standard.

Best regards



Grad Eng. Holger Romberg
Laboratory Manager



M.Sc. Christoph Frömter
Test Engineer