



Chaussée de Vilvorde, 156  
 Vilvoordsesteenweg 156  
 B-1120 Bruxelles/Brussel  
 Tel.: 32 (0)2 264 03 60  
 Fax: 32 (0)2 268 89 58  
 http://www.apragaz.com  
 info@apragaz.com



<b>EC TYPE - EXAMINATION</b>		<b>Certificate N°</b>
<b>In accordance with module B of Directive 2014/90/EU on Marine Equipment</b>		<b>20/IT/4694-0-REV 0</b>
<b>Manufacturer</b>	Name	ANAF FIRE PROTECTION S.P.A.
	Address	Via del Commercio 4 IT - 27020 Torre d'Isola (Pavia) ITALY
<b>Concerned Equipment:</b> Portable Fire Extinguishers (Water Based Stored Pressure)		
<b>Type:</b> FS9-LH & FS9-LHZ / FS9-LHF & FS9-LHFZ		
<b>Technical documents ref.:</b> 09.886F.F000.00 & 09.888F.F000.00 / 09.896F.F000.00 & 09.898F.F000.00		
<b>Capacities:</b> 9l <b>Fire Rating :</b> 34A - 233B / 34A - 233B - 75F		
<b>Set pressure:</b> max. 17,48 bar (+60°C) <b>Test pressure:</b> 25 bar		
<b>Bursting pressure:</b> ≥55 bar		
<b>Service temperature range:</b> min. +0°C / max. +60°C		
<p>The manufacturer is allowed to affix the marine CE mark  (followed by the NoBo n° and the year of manufacturing) to approved equipment in the conditions described in article 10 of the Directive , only if the requirements stated in module D are fully complied with.</p> <p style="text-align: center;"><b>The approval is valid until 02/11/2025</b></p>		
<p>APRAGAZ, acting within the scope of its notification for the above mentioned Directive, certifies that the types of equipment defined here above are conform to the requirements of the EN 3.7 &amp; EN 3.8 in force and to the Marine Equipment Directive 2014/90/EU (as amended), on base of the documentation and samples supplied for review and approbation.</p>		
Date : <b>02/11/2020</b>	Name : <b>B. NEVE, ir</b>	Position <b>General Manager</b>
Notified body identification number :	<b>0029</b>	Signature
Notified body :	<b>APRAGAZ VZW / ASBL</b>	
Notified body reference :	<b>4434 P 000</b>	